

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

6443

INVESTIGATIONS AND RECOMMENDATIONS FOR ACTION TO BE TAKEN

Referring to the attached schedules of inspection and test results, and subject to the limitations at D:

There are no items adversely affecting electrical safety.

or The following observations and recommendations for action are made

Item No.

Observations

Code†

- 1 No visual evidence of metal step bar in kitchen
- 2 No Suse in switch set - socket behind washing machine
- 3 Socket less than 30cm away from cooker space C3
- 4 Bathrooms Sanitised (done)
- 5 Grommet + E cable drop to Taps! shower on long 2 C3
- 6 E/C Circuit on Shamp M.C. B C3
- 7 Shamp Suse in Spar Soc Kitchen San (on Shamp) C2
- 8 Shelves in Kitchen unit in front of main Suse missing. C3
- 9 Lamp Meter tails C3
- 10 Lamp in Bathroom light not working (done) C3
- 11 Plastic consumer unit C3
- 12 Smoke alarm and carbon monoxide working C3
- 13 Gas hob. Built in single electric oven or multi plug. C3
- 14 Electric shower short store C3
- 15 Oil accessories like kettle C3

Additional pages? No Yes

Specify page No(s):

Immediate remedial action required for items:

Urgent remedial action required for items:

Further investigation required without delay for items:

Improvement recommended for items:

* The completed report should preferably be reviewed by another skilled person competent to confirm that the declared overall condition of the electrical installation is consistent with the inspection and test results, and with the observations and recommendations for action (if any) made in the report.

This report is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. © Copyright Certsure LLP (January 2015)

† Myself, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below); particulars of which are described on page 1 (see C), having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the schedules (see H) provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing (see D).

I/We further declare that in my/our judgement, the overall assessment of the installation in terms of its suitability for continued use is **SATISFACTORY / UNSATISFACTORY** Delete as appropriate (see F) at the time the inspection was carried out, and that it should be further inspected as recommended (see I).

* An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that further investigation without delay (F) is required.

INSPECTION, TESTING AND ASSESSMENT BY:

Signature:

Name: **Electrician**

(CAPITALS)

Date: **5/11/18**

Position:

REPORT REVIEWED AND CONFIRMED BY:

Signature:

Name: **[Signature]**

(CAPITALS)

Date: **6/11/18**

INVESTIGATIONS AND ADDITIONAL PAGES

Schedule of Inspections: Page(s) No 4, 5, 6

Additional pages, including data sheets for additional source(s): Page No(s)

Schedule of Circuit Details for the Installation: Page No(s) 7

Schedule of Test Results for the Installation: Page No(s) 7

The pages identified are an essential part of this report. The report is valid only if accompanied by all the schedules and additional pages (identified above).

Please see the Guidance for Recipients on the reverse of this page.